

STATEMENT OF BASIS
CITY OF LONG BEACH
NPDES PERMIT NO. WA0022489

The purpose of this Statement of Basis is to explain the need to modify the Permit to remove the testing for chlorine residual for the City of Long Beach's newly upgraded Wastewater Treatment Plant.

I. GENERAL INFORMATION

- A. Permittee: City of Long Beach
 6th Street Northeast
 Long Beach, Washington 98631
- B. Discharge Locations: Drainage Channel to Tinker Lake to Willapa Bay
 Latitude: 46° 21' 19"
 Longitude: 124° 02' 51"

II. REQUEST FOR MODIFICATION:

Phase one of the wastewater treatment plant upgrade has been completed, the plant is using a low pressure ultraviolet disinfection system and not chlorine. The existing permit requires that total chlorine residual is to be reported five days a week.

Modifications made to the permit include removing chlorine from the Effluent Limitations in S1 of the permit:

Another modification made to the permit is removing chlorine from the monitoring schedule found in S2 of the permit.

This Statement of Basis will serve as an amendment to the Fact Sheet and Permit.